

SC-ST-P Smart Temperature Controller: BACnet Object table

Object Name	Type & Instance	Object Property (R/W)	Range
ST-SC-P	Example - Device 662001	Model_Name (R)	
		Application_Software_Version (R)	
		Object_Identifier (R)	
		Object_Name (R,W)	32 characters (max.)
		Max_Master (R,W)	1- 127

Object Name	Type & Instance	Object Property (R/W)	Description	Range & Definition
Binary Values				
Cooling Direct/ Reverse Acting	BV-0	R/W	Cooling Direct/ Reverse Acting	0: direct 1: reverse
Heating Direct/ Reverse Acting	BV-1	R/W	Heating Direct/ Reverse Acting	0: direct 1: reverse
Temp/SP Displaying	BV-2	R/W	Display present value of temperature or setpoint for default display	0: display temperature 1: display SP
Device On-Off Control	BV-3	R/W	Thermostat On/Off	0: Off, 1: On
Temperature Scale	BV-4	R/W	°C/ °F	0: °C, 1: °F
ESI contact definition	BV-5	R/W	ESI contact definition	0:-N.O., 1: N.C.
ESI contact type	BV-6	R/W	ESI contact type	0: PIR, 1: Window switch
Fan DPS Contact Definition	BV-7	R/W	Fan diff. pressure switch (DPS) Contact Definition	0: N.O., 1: N.C.
Fan High Speed Relay Control	BV-8	R/W	Fan Speed Hi Relay Control	0: Off, 1: On Note: This is writable only when the value of AV-15 equals 512 (or larger than 512 but the bit 9 of AV-15 should be 1.)
Fan Med Speed Relay Control	BV-9	R/W	Fan Speed Med Relay Control	0: Off, 1: On Note: This is writable only when the value of AV-15 equals 512 (or larger than 512 but the bit 9 of AV-15 should be 1.)
Fan Low Speed Relay Control	BV-10	R/W	Fan Speed Low Relay Control	0: Off, 1: On Note: This is writable only when the value of AV-15 equals 512 (or larger than 512 but the bit 9 of AV-15 should be 1.)

Binary Inputs				
Windows Status	BI-0	R	Status of Windows	0: Close or Not Applicable, 1: Open
Fan DPS Status	BI-1	R	Status of fan DPS contact	0: Fan Stop, 1: Fan Run
Cooling-heating Status	BI-2	R	Status of cooling/heating	0: Close & Off, 1: Open & On

			control output	
Fan Speed Hi Relay Status	BI-3	R	Fan Speed Hi Relay Status	0: Off, 1: On
Fan Speed Med Relay Status	BI-4	R	Fan Speed Med Relay Status	0: Off, 1: On
Fan Speed Low Relay Status	BI-5	R	Fan Speed Low Relay Status	0: Off, 1: On

Analogue Values

User Setpoint Temperature	AV-0	R/W	User setpoint temperature (SP)	°C: 0.0 - 50.0°C °F: 32.0 - 122.0° Resolution: 0.5°C/°F High limit defined by AV11 Low limit defined by AV10.
Temperature override	AV-1	R/W	Assigned current temperature	-99.9~999.9°C /°F
Timer Off	AV-2	R/W	Countdown timer	1 - 24 if timer available 0 if OFF Resolution: 1
Hr-Running Time	AV-3	R/W	Running time of Valve (Hr.)	0 - 65535 for reading 0 - 30000 for writing Resolution: 1
M-Running Time	AV-4	R/W	Running time of Valve (M.)	0 - 59 Resolution: 1
Sec-Running Time	AV-5	R/W	Running time of Valve (Sec.)	0 - 59 Resolution: 1
Occupied Deadband	AV-6	R/W	Occupied deadband	°C: 0.0 - 10.0 °C °F: 0.0 - 18.0 °F Resolution: 0.5
Integral Time	AV-7	R/W	Integral Time and output cycle time	0 - 500 (sec.) Resolution: 10
Minimum Analog Output	AV-8	R/W	Minimum output voltage in digital value for AO when reach Low limit	0 - 125 (LSB) Resolution: 1
Span Offset	AV-9	R/W	Span offset	-55~0 (LSB) Resolution: 1
Low Setpoint Limit	AV-10	R/W	Low limit for setpoint temperature	°C: 0.0°C ~ AV-11 °F: 32.0°F ~ AV-11 Resolution: 1
High Setpoint Limit	AV-11	R/W	High limit for setpoint temperature	°C: AV-10~ 50.0°C °F: AV-10 ~ 122.0°F Resolution: 1
Temperature Offset	AV-12	R/W	Offset for current temperature	°C: -10.0 - 10.0 °C °F: -18.0 - 18.0 °F Resolution: 0.1
Proportional Band or Stage Width	AV-13	R/W	Proportional band	°C: 0.0 - 10.0 °C °F: -0.0 - 18.0 °F Resolution: 0.1
Fan Stage Differential	AV-14	R/W	Fan Stage Differential	°C: 0.1 - 1.0 °C °F: 0.1 - 1.8 °F Resolution: 0.1

Lock	AV-15	R/W	Lock	Bit Definition --- Bit 0: MODE button 1~5: Reserved 6: Disable PIR/occupancy detection 7: Disable Window open detection 8: Lock the modification for communication parameters, i.e. baud rate, MAC address and device instance 9: Override/DOs set by device (0) or BMS (1) 10: Disable local thermostat on/off setting 11: Disable local Fan speed setting *Bit Value 0: Unlock / enable 1: Lock / disable Examples: 0 - Unlock/enable all 1 - Lock MODE Button 64 - Disable PIR/occupancy contact detection 256 - Lock the modification for communication parameters 512: Override/DOs set by BMS 4095 - Lock/disable all
MAC Address	AV-16	R/W	MAC address	0 - 127 (confined by Max-master) Resolution: 1 (Note: Changing this value requires bit 8 of AV-15 to be unlocked. See LOCK (AV-15) for details)
Device Instance	AV-17	R/W	Device instance	0 - 4194302 Resolution: 1 (Note: Changing this value requires bit 8 of AV-15 to be unlocked. See LOCK (AV-15) for details)
Standby Cooling/ Heating Setpoint Gap	AV-18	R/W	Standby Cooling/ Heating Setpoint Gap from Occupied Cooling/ Heating Setpoint	°C: -10.0 - 10.0 °C °F: -18.0 - 18.0 °F Resolution: 0.5
Unoccupied Cooling/ Heating Setpoint Gap	AV-19	R/W	Unoccupied Cooling/ Heating Setpoint Gap from Occupied Cooling/ Heating Setpoint	°C: -10.0 - 10.0 °C °F: -18.0 - 18.0 °F Resolution: 0.5
Standby timer	AV-20	R/W	Standby timer	0 - 24 Hours Resolution: 0.5
Unoccupied timer	AV-21	R/W	Unoccupied timer	0 - 24 Hours Resolution: 0.5
Window switch grace timer	AV-22	R/W	Window switch grace timer	10 - 120 secs Resolution: 10

Multistate Values

Fan Mode	MSV-0	R/W	Fan Mode	1: Off 2: Low 3: Med 4: High 5: Auto
----------	-------	-----	----------	--

System Mode	MSV-1	R/W	System Mode	1 - 4 but not all selectable depending on model and working status. Example: Mode is 1 or 3 available if working in cooling Mode is 2 or 4 available if working in heating. 1: Cooling mode 2: Heat mode 3: Ventilation & cooling mode 4: Ventilation & heating mode
Sleep	MSV-2	R/W	Sleep	1: Disable, 2: 0 hr. sleep 3: 0.5 hr. sleep 4: 1 hr. sleep 5: 1.5 hrs. sleep 6: 2 hrs. sleep
Source of Current Temperature	MSV-3	R/W	Present Temperature is getting from built-in temperature Sensor, remote temperature sensor, or assigned through Network	0: built-in temp. sensor 1: remote temp. sensor 2: assigned through Network
Lowest Fan Speed	MSV-4	R/W	Lowest Fan speed in Auto Fan mode	1: Stop 2: Low 3: Med. 4: Hi.
Fan Speed Status	MSV-5	R	Fan Speed Status	1: Stop 2: Low 3: Med. 4: Hi.
Occupancy Mode	MSV-6	R	Current Occupancy Mode	1: Occupied 2: Standby 3: Unoccupied
Baud Rate	MSV-7	R/W	Baud Rate	1: 9600 bps 2: 19200 bps 3: 38400 bps 4: 57600 bps 5: 76800 bps 6: Auto (Note: Changing this value requires bit 8 of AV-15 to be unlocked. See LOCK (AV-15) for details)

Analogue Inputs				
Current temperature	AI-0	R	Current Temperature	-99.9 - 999.9°C/°F
Current Active Setpoint	AI-1	R	Current Setpoint Used	-99.9 - 999.9°C/°F
Built-in Sensor	AI-2	R	Built-in Sensor Temperature	-99.9 - 999.9°C/°F
Remote Sensor	AI-3	R	Remote Sensor Temperature	-99.9 - 999.9°C/°F
Cooling Output	AI-4	R	Cooling Output Percentage	0 – 100%
Heating Output	AI-5	R	Heating Output Percentage	0 – 100%
Standby Cooling Setpoint	AI-6	R	Standby Cooling Setpoint	-99.9 - 999.9°C/°F
Standby Heating Setpoint	AI-7	R	Standby Heating Setpoint	-99.9 - 999.9°C/°F



Unoccupied Cooling Setpoint	AI-8	R	Unoccupied Cooling Setpoint	-99.9 - 999.9°C/°F
Unoccupied Heating Setpoint	AI-9	R	Unoccupied Heating Setpoint	-99.9 - 999.9°C/°F

Whilst every effort has been made to ensure the accuracy of this specification, Sontay cannot accept responsibility for damage, injury, loss or expense from errors or omissions. In the interest of technical improvement, this specification may be altered without notice.